



REPLY TO
ATTENTION OF

DEPARTMENT OF THE ARMY
FORT WORTH DISTRICT, CORPS OF ENGINEERS
P. O. BOX 17300
FORT WORTH, TEXAS 76102-0300

September 9, 2003

Contracting Division

Planholders:

1. Reference is made to Solicitation No. DACA63-03-B-0010, FY 03 PN 059443, Brigade Command and Control Facility, Fort Hood, Texas.
2. Enclosed is an answer to a contractor question that was submitted to this office for the referenced solicitation.
3. This enclosure is for information purposes only and is not a part of the Invitation For Bid.

Sincerely,

A handwritten signature in black ink, appearing to read "R. D. Feller", is written over a horizontal line.

Richard D. Feller
Contract Specialist

Enclosure

Q1. Section 08700 was revised to state in Paragraph 2.13 that "Hinges, locks, latches, and associated hardware are to be BHMA 630 finish", which is satin stainless steel. All of the hinges are listed in the hardware schedule with A2111, A8111, A8133, or A8112 designations. None of these hinge designation numbers are for stainless steel hinges. They are all for brass or steel based hinges. Please clarify what type of hinge is to be provided.

A1. The base material and finish for all "Hinges, locks, latches, and associated hardware are to be BHMA 630 finish". The remaining portion of the hardware schedule designations remain applicable. But the basic material is to be satin stainless steel.